

Magnetic Door Holders

DH-171SQ DH-151SQ Flush-mount Surface-mount

The UL Listed SECO-LARM Magnetic Door Holders are designed for virtually any remote door release applications, whether residential or commercial. Fail-safe operation, tri-volt coils, and adjustable armature plate allows for easy and flexible installation.

Features:

- For use with door closers to control the release and closing of residential, commercial, and public area doors
- Adjustable armature plate reduces installation time and adjusts to door alignment changes
- Low profile design
- Holding force 33-lb (15kg)
- 3 voltages: 12/24 VAC/VDC, and 120VAC
- Cast aluminum faceplate
- No residual magnetism for easy release
- Built-in voltage spike suppressor
- Use with SECO-LARM door closers
- Extension bars available: 1/2", 3/4", 1", 2" (13mm, 19mm, 25mm, 50mm)





DH-171SQ




DH-151SQ




Specifications:

Model		DH-151SQ	DH-171SQ
Installation		Surface-mount	Flush-mount
Operating voltage		12/24 VAC/VDC, 120VAC	
Current draw		52mA@12VAC, 60mA@12VDC	
		27mA@24VAC, 31m@24VDC	
		24mA@120VAC	
Holding force		33-lb (15kg)	
Dimensions	Magnet	2 ³ / ₄ "4 ⁹ / ₁₆ "x3"	2 ³ / ₄ "x4 ⁹ / ₁₆ "x2 ¹ / ₁₆ "
		(70x116.5x76 mm)	(70x116.5x52 mm)
	Armature	2 ⁹ / ₁₆ "x2 ⁹ / ₁₆ "x 1 ⁹ / ₁₆ " (65x65x40 mm)	
Magnet box weight		1-lb 6.4-oz (635g)	1-lb 1.5-oz (496g)
Door armature weight		8.1-oz (230g)	

Dimensions:



DH-171SQ



Back

SECO-LARM[®] U.S.A., Inc.

16842 Millikan Avenue, Irvine, CA 92606 **Phone:** (949) 261-2999 | (800) 662-0800 **Fax:** (949) 261-7326 **Website:** <u>www.seco-larm.com</u> **Email:** <u>sales@seco-larm.com</u> Copyright 2016 © SECO-LARM U.S.A., Inc. All rights reserved. All trademarks are the property of SECO-LARM U.S.A., Inc. or their respective owners. The SECO-LARM policy is one of continual development. For that reason, SECO-LARM reserves the right to change prices and specifications without notice. SECO-LARM is not responsible for misprints.

SECO-LARM® **ENFORCER®** CRIMEBUSTER® CBA **SLI**

PI_DH-1x1SQ_160919.docx

